



Government of Karnataka

OFFICE OF THE ASSISTANT EX.ENGINEER. P R ENGINEERING SUB DIVISION
KRISHNARAJAPURAM. BENGALURU URBAN DISTRICT BENGALURU KARNATAKA

Ref: AE/PRED/BNG/EAST/23-24


Date: 16th May 2023

BUILDING SAFETY / STABILITY CERTIFICATE

We hereby certify that “GENIUS GLOBAL SCHOOL”, Sy no 21 Kodathi to Huskur Road Sarjapur Road, Kodathi Village Carmelaram Post Varthur Hobli Bengaluru-560035 comprised of G + 4 Floor leased by “SHARADA EDUCATIONAL TRUST ” have complied with the building bye laws in accordance with rule of STATE /UT and incorporate the provisions of building by safety as specified in Nation Building Code 2005, 2016 and as amended thereafter and has been verified by the concern officer on 16/05/2023 in the presence of secretary Mr. C.Venkataswamy Reddy that “GENIUS GLOBAL SCHOOL”, Sy no 21 Kodathi to Huskur Road Sarjapur Road , Kodathi Village Carmelaram Post Varthur Hobli Bengaluru-560035 . The building has been constructed as a framed structure and the construction work has been completed in accordance with the sanctioned plans , general safety, light, air and ventilation is adequate.

We here by certify that the said above building /premises is structurally safe and fit for running the school. This certificate is effect from 16th May 2023 for a period of 50 years in accordance with rules.

Paulhakshoil
ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ
ಹೆಚ್.ಎ.ಎಲ್. ಎನ್ ಕ್ಲರರ್ಸ್ ಕುಡ್ ವಿಭಾಗ
ಬೆಂಗಳೂರು-37



OFFICE OF THE DISTRICT FIRE OFFICER
SARJAPUR ROAD FIRE STATION
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

C.NO: 02/DFO/SRFS/BNG/2023.

"Annexure-2"

OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka State Fire & Emergency Services
Sarjapura Road Fire Station
Bengaluru-560 035.

Date: 21/01/2023

To,

The Authorized Signatory
M/s. Genius Global School,
Sy No.21, Kodathi to Huskur Road,
Kodathi, Bangalore-560 035.

Sir,

Sub: Issue of "Fire Safety Compliance report" with respect to fire prevention, fighting and evacuation measures maintained at "M/s. Genius Global School, Sy No.21, Kodathi to Huskur Road, Kodathi, Bangalore-560 035".

Ref: 1) This office FSR No.02/Dfo/SRFS/Bng/FSR/2023. Dt:-21-01-2023.

2) Your request letter dated: 09-01-2023.

<<<<>>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of "M/s. Genius Global School, Sy No.21, Kodathi to Huskur Road, Kodathi, Bangalore-560 035". With a Condition to fulfill the recommendations and compliance the same within 3 months,

With reference cited (2) above, the management of "M/s. Genius Global School" had requested for the fire safety compliance report from our department. In this regard the above addressed educational building was inspected by me on 10/01/2023 for issue fire safety Compliance report.


Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to. "M/s. Genius Global School, Sy No.21, Kodathi to Huskur Road, Kodathi, Bangalore-560 035". Subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report. "This report is valid for one year from the date of issue of this report and is renewable without fail".



Yours faithfully,



DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bengaluru-560 035.



OFFICE OF THE DISTRICT FIRE OFFICER
SARJAPUR ROAD FIRE STATION
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

C.NO: 02/DFO/SRFS/BNG-2023.

OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka State Fire & Emergency Services
Sarjapura Road Fire Station
Bangaluru-560 035.
Date: 21/01/2023

To,
The Authorized Signatory
M/s. Genius Global School,
Sy No.21, Kodathi to Huskur Road,
Kodathi, Bangalore-560 035.

ANNEXURE-B
Group B Educational Buildings

Sub: Issue of 'Fire Safety Recommendation Certificate' with respect of fire prevention, fire fighting and evacuation measures required at "M/s. Genius Global School, Sy No.21, Kodathi to Huskur Road, Kodathi, Bangalore-560 035".

Ref: Yours Request Letter. Dated: 09/01/2023.

><<<*@*<<<<

With reference to the subject cited above, the premises "M/s. Genius Global School, Sy No.21, Kodathi to Huskur Road, Kodathi, Bangalore-560 035". Was inspected by me on **10-01-2023** with respect to fire prevention, fire fighting & evacuation measures to be complied in the above Premises and has submitted The details as Under.

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	The Authrized Signatory M/s. Genius Global School, Sy No.21, Kodathi to Huskur Road, Kodathi, Bangalore-560 035.
02	Name and Address of the premises.	:	M/s. M/s. Genius Global School, Sy No.21, Kodathi to Huskur Road, Kodathi, Bangalore-560 035.
03	Name and address of the Building owner	:	Mr.C Venkataswami reddy, S/o Chikkaveerappa, No.69, Behind Deepa Nursery, Kodathi Village, Carmelaram Post, Bangalore-560 035.
04	Number of buildings	:	One building
05	Number of floors	:	Ground + 04 Upper floors




06	<u>Floor-wise details of occupancy:-</u>		
	Ground floor	:	07 Class Rooms, 01 Staff room, 01 Reception, 01 Advise room, 01 Store room, 01 Principal room and 02 wash Rooms.
	1 st floor	:	08 Class Rooms, 01 Library and 02 wash Rooms.
	2 nd floor	:	08 Class Rooms and 02 wash Rooms.
	3 rd floor	:	08 Class Rooms, 01 Computer Lab, 01 Science lab and 02 wash Rooms.
	4 th floor	:	05 Class Rooms, 01 Hall and 01 wash Room.
07	Height of the building	:	14.80 Mtrs.
08	Site area	:	7,891.37 Sq. Mtrs
09.	Built-up area of each floor:-		
	Ground floor	:	3738.41 Sq. Mtrs
	1 st floor	:	3738.41 Sq. Mtrs
	2 nd floor	:	3738.41 Sq. Mtrs
	3 rd floor	:	3738.41 Sq. Mtrs
	4 th floor	:	156.70 Sq. Mtrs
10.	Total built-up area	:	15,110.34 Sq. Mtrs.
11.	Surrounding properties:-		
	South (Front)	:	08.00 mtrs wide Kodathi to Huskuru main road.
	North (Rear)	:	Play Ground.
	East (Side)	:	Agriculture land.
	West (Side)	:	Agriculture land.
12.	<u>Set-back area available around the building :-</u>		
	South (Front)	:	Minimum 06.00 mtrs.
	North (Rear)	:	10.00 mtrs
	East (Side)	:	03.00 mtrs
	West (Side)	:	06.00 mtrs.

B. On inspection of this Industrial premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The Premises is accessible from 08.00 mtrs wide Kodathi to Hosur main road located on Southern side the road is hardened to carry the Weight of 45.000 Kgs.	Complied



10.	Escape routes	Escape routes have been Marked in Which visibly to guide the students make to safer Places.	Complied.
11.	Fire order	Fire order board has been displayed near each staircase of ground floor with emergency Telephone Numbers of Sarjapura Road Fire Station i.e. 25746166 & 101 and telephone numbers of nearest Ambulance Service & Management.	complied
12	No Smoking board.	No Smoking board shall be displayed.	Complied
13	Fire Siren	A Fire Siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.	Complied
14	Nominate one fire Nodal Officer	One non teaching staff has been nominated as fire nodal officer for the school premises.	Complied
15	Fire fighting training	Not trained	The 40% of staff or employees Should Be got trained in fire prevention And fire fighting evacuation measures at R.A.Mundkur Fire & Emergency Services Academy, B.G.Road, Bangalore-29.
<p>General Fire precaution measures :-</p> <p>A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B. Accumulation of combustible waste in and around the premises should be avoided.</p> <p>C. The exit ways shall be always kept clear without any obstruction.</p> <p>D. Liquefied petroleum gas should be not stored in the building.</p> <p>E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.</p> <p>F. During the class hours the class room doors shall not be locked from inside to outside.</p> <p>G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14th of every year by conducting fire safety drills with co-ordinate with Fire Service Department.</p>			



02.	No. of entrances	One entrance / exit have been Provided.	Complied																					
03.	Width of entry / exit	Entrance / Exit- 5.30 mtrs.	Complied																					
04.	Diesel generators.	Not Provided.	As Proposed to provide One suitable Capacity of generator should be provided																					
05.	No. of staircases available	<table border="1"> <tr> <td>Nos. of staircases</td> <td>:</td> <td>01</td> </tr> <tr> <td>Width of staircases</td> <td>:</td> <td>1.70 mtrs</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>30 cm</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>15 cm</td> </tr> <tr> <td>Nos. of riser per flight</td> <td>:</td> <td>12</td> </tr> <tr> <td>Height of handrails</td> <td>:</td> <td>0.90 mtrs</td> </tr> <tr> <td>Head room clearance</td> <td>:</td> <td>3.30 mtrs</td> </tr> </table>	Nos. of staircases	:	01	Width of staircases	:	1.70 mtrs	Width of treads	:	30 cm	Height of risers	:	15 cm	Nos. of riser per flight	:	12	Height of handrails	:	0.90 mtrs	Head room clearance	:	3.30 mtrs	Complied.
Nos. of staircases	:	01																						
Width of staircases	:	1.70 mtrs																						
Width of treads	:	30 cm																						
Height of risers	:	15 cm																						
Nos. of riser per flight	:	12																						
Height of handrails	:	0.90 mtrs																						
Head room clearance	:	3.30 mtrs																						
06.	Fire extinguisher	06 Nos. of ABC fire extinguishers, each Of 6 kg capacity, 02 Nos. of CO2 fire extinguishers, each Of 4.5 kg capacity have been provided in The Building.	Complied.																					
07.	First aid Hose reel hose.	05 No's of Hose Reel Hose has been provided near the Staircases Hose Reel Hose of 19 mm size of adequate length to reach the farthest point of floor has been provided with shut off branch having a nozzle of 5 mm size. Have been Provided.	Complied.																					
08.	Terrace tank over respective tower terrace.	20,000 liters capacity of terrace tank has been provided.	Complied.																					
09.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	A booster pump has been installed at the terrace level capable of delivering 450 liters of water per minute.	Complied.																					



H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing "**Fire Safety Recommendation**" to "M/s. Genius Global School, Sy No.21, Kodathi to Huskur Road, Kodathi, Bangalore-560 035". Subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 3 months and compliance from the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable."

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.



Yours faithfully,

 2.11/23
DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bengaluru-560 035.